

CDC Position on Bipolar Ionization

Thank you for your question. Although this was pointed out in the earlier CDC responses, it is important for me to re-emphasize that CDC does not provide recommendations for, or against, any manufacturer or manufacturer's product. While bi-polar ionization has been around for decades, the technology has matured and many of the earlier potential safety concerns are reportedly now resolved. If you are considering the acquisition of bi-polar ionization equipment, you will want to be sure that the equipment meets UL 2998 standard certification (Environmental Claim Validation Procedure (ECVP) for Zero Ozone Emissions from Air Cleaners) which is intended to validate that no harmful levels of ozone are produced. Relative to many other air cleaning or disinfection technologies, needlepoint bi-polar ionization has a less-documented track record in regards to cleaning/disinfecting large and fast volumes of moving air within heating, ventilation, and air conditioning (HVAC) systems. This is not to imply that the technology doesn't work as advertised, only that in the absence of an established body of evidence reflecting proven efficacy under as-used conditions, the technology is still considered by many to be an "emerging technology". As with all emerging technologies, consumers are encouraged to exercise caution and to do their homework. Consumers should research the technology, attempting to match any specific claims against the consumer's intended use. Consumers should request efficacy performance data that quantitatively demonstrates a clear protective benefit under conditions consistent with those for which the consumer is intending to apply the technology. Preferably, the documented performance data under as-used conditions should be available from multiple sources, some of which should be independent, third party sources.



888-588-4079 | pandemicsolutions.net | info@pandemicsolutions.net